



NORTHERN  
LAND COUNCIL

## ADDENDUM NUMBER 2

Request for Tender: NLC-1080158

*Our Land, Our Sea, Our Life*

TO ALL TENDERERS

15 December 2023

### Katherine - NLC-22/23 - 002 KATHERINE - NLC KATHERINE OFFICE PRECINCT – CONSTRUCT


**Closing date for tenders for this project is extended to:  
2.00pm (ACST) Thursday, 25 January 2024**

NOTE: If you have already submitted a Tender, you may resubmit a new Tender that will supersede the original submitted. This new Tender should be marked as “supersedes previous Tender”.

The above tender is amended as follows:

#### TENDER ADDENDUM 2:

No.	Question/Comment	Response
1.1	Elevations on drawings A130 & A231 entry door frames as ACCOYA Timber framing while Window schedule notes Aluminium finish A601 – which is correct?	D.P1 01 – Accoya D.P1 02 – Accoya D.P1 13 - Accoya D.P2 01 – Accoya  The remainder of the aluminium doors and windows are to be anodised aluminium.
1.2	Please confirm what type of roof sheeting to be used on Carparks and Pavilions.  Drawings states Custom Orb Colorbond, however the FF&E Schedules states Custom Orb Zinalume.	Zinalume Custom orb.
1.3	There is an issue with the colours that have been chosen. The Spearmint, Pinnacle, Vintage are all non std 3D tile colours and have an MOQ of 14 packs.  3D tiles S5.32 profile, 6 Circles per pack (3 @ Concave and 3 @ Convex), includes mounting clips	Please go with the below colours: <ul style="list-style-type: none"><li>- Flatiron</li><li>- Muralla</li><li>- Beehive</li><li>- Falling Water</li></ul>

	<p>Pls advise architect of colour issue and advise new colours based on the attached / below</p> 	
1.4	<p>The successful Tenderer must comply with all conditions of accreditation under the WHS Accreditation Scheme – is this ISO accredited or is it FSC accredited? If it is FSC accredited would a contractor be accepted if they were to apply for FSC prior to tender being submitted?</p>	<p>To provide further clarity, FSC accreditation is required for this project, with the contractor required to be accredited at the time of tender award.</p>
1.5	<p>Are you able to provide a Word version of the Response Schedule to allow easier completion of tendering responses?</p>	<p>Yes, please see attached</p>
1.6	<p>Assuming the new closing date referred to in addendum 01 applies to NLC-22/23 - 002 KATHERINE - NLC KATHERINE OFFICE PRECINCT – CONSTRUCT, are you also extending the period for requests for information beyond the current 15 December?</p>	<p>Correct, the new cut off date for requests for information is now Thursday 18 January.</p>

This addendum consists of two (2) pages excluding the attached Word version of the Response Schedule.

**Please acknowledge and confirm receipt of the Addendum 1 in your Response Schedule.**

For further information contact: email [tenderenquiries@nlc.org.au](mailto:tenderenquiries@nlc.org.au)